Liverpool Plains Water Supply Systems - Sample Results (μg/L)											
PFAS Category	Current Australian Drinking Water Guideline Recommendation	Proposed Australian Health- based Drinking Water Guideline Recommendation	Blackville Bore Treated Water	Caroona Bore Treated Water	Premer Bore Treated Water	Spring Ridge Bore Treated Water	Wallabadah Bore Treated Water	Quirindi Bore Treated Water	Quipolly Dam Supply Treated Water (Werris Creek)	Walhallow Rising Main Treated Water	Willow Tree Rising Main Treated Water
			Sampled on 6/12/2024	Sampled on 5/12/2024	Sampled on 6/12/2024	Sampled on 6/12/2024	Sampled on 4/12/2024	Sampled on 4/12/2024	Sampled on 5/12/2024	Sampled on 5/12/2024	Sampled on 4/12/2024
PFOA	Based on human health considerations, the concentration of PFOA in drinking water should not exceed 0.560 µg/L	Based on human health considerations, the concentration of PFOA in drinking water should not exceed 0.2 μg/L	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001
PFOS	concentration of PFOS and	Based on human health considerations, the concentration of PFOS in drinking water should not exceed 0.004 μg/L	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001
PFHxS	considerations, the same of the	Based on human health considerations, the concentration of PFHxS in drinking water should not exceed 0.03 µg/L	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001
PFBS	No health-based guideline value in the current Guidelines	Based on human health considerations, the concentration of PFBS in drinking water should not exceed 1 µg/L	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001